
PROJECT:	UNCP West Hall Parking (Lot 21) Pavement Improvement	NO.:	02
OWNER:	University of North Carolina at Pembroke	DATE OF ISSUANCE:	4/22/2024
		ENGINEER:	REI Engineers
		REI PROJECT NO:	022CLT-296

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 2/3/2023 as noted below.

This addendum consists of one (1) page.

QUESTIONS/CLARIFICATIONS

1. "What is height of the Security Fence?" **The height of the fence should be a minimum of 6 feet.**
2. "We contractor need to install temporary construction fence. Are cones and tape good enough to for this project?" **The University is looking for a continuous barrier around the construction area.**
3. "On plan sheet C-103, there is mentioned in the Site Plan Notes some details regarding the new chain link fence to be installed. However, it does not cover how tall the fence should be and there is no detail showing this, 6' or 8'?" **The height of the fence should be a minimum of 6 feet.**
4. "On plan sheet C-101, there is a "STOP" sign to be removed. Can this same sign be installed as shown on plan sheet C-103 or does the Owner have a sign they would rather be installed or should the contractor figure a new standard "STOP" sign R1-1? What size (18", 24" or 30")?" **The existing stop sign shall be removed and taken to the Facilities Building for storage. The University will provide the new stop sign to be installed.**

ALL OTHER REQUIREMENTS AND PROVISIONS OF THE BIDDING DOCUMENTS REMAIN UNCHANGED. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM. FAILURE TO DO SO MAY BE CAUSE FOR REJECTION OF THE BID.

END OF ADDENDUM